



NOTE:
 1. REINFORCING STEEL SHALL BE GRADE 40 OR GRADE 60.
 2. CONCRETE SHALL BE PER DOT/APWA SPECIFICATION 6-02.3(2), CLASS B.

PIPE DIAMETER	CONCRETE CLASS B	DIMENSION X
	APPROX CY	
12"	0.3	2'-4"
18"	0.4	2'-11"
24"	0.5	3'-6"
30"	0.6	4'-1"
36"	0.7	4'-8"
42"	0.8	5'-3"
48"	0.9	5'-10"
54"	1.1	6'-5"
60"	1.3	7'-0"

PIPE ANCHOR

SEWER STANDARD DETAIL

**SNOQUALMIE PASS
 UTILITY DISTRICT**

FILE	SCALE	DATE
SPUDTS6	NTS	7/22/04